



Hercules Incorporated
West 7th Street
P.O. Box 1937
Hattiesburg, MS 39401
(601) 545-3450

July 1, 1988

CERTIFIED MAIL
RETURN RECEIPT REQUESTED
#P-004-497-695

Earl Mahaffrey
Bureau of Pollution Control
P.O. Box 10385
Jackson, MS 39209

Dear Mr. Mahaffrey:

The purpose of this letter is to inform you that on June 29, 1988, while repairing an industrial sewer line in our synthetic resin area, a small seep hole developed into our non-contact cooling water discharge system. This problem was promptly sand bagged and then corrected with a minimal amount of process wastewater entering the cooling water discharge system.

If I can answer any additional question, please call me.

Very truly yours,

Charles Jordan
Environmental Supervisor

CJ/dc

